

FIRE SAFETY CERTIFICATE

No. 112

Dated:21.05.2024

Certified that the **M.S.CHARITABLE TRUST MEENAMPARK VIDHYALAYA SCHOOL** (name of the building or premises) at **SALEM - MECHERI MAIN ROAD,PONMALAI PERIYASATHAPADY VILLAGE, METTUR TK, SALEM DISTRICT PIN: 636 451** (address) comprised of Main block with Ground floor and first floor along with Block II - Auditorium owned/occupied by **MEENAMPARK VIDHYALAYA SCHOOL** (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on **21.05.2024** (date of inspection) in the presence of **PON SELVADURAI Meenampark Vidhyalaya School** (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes **X** (X/ XII) With effect from **21.05.2024** for a period of **ONE year** in accordance with rule and subject to compliance of specific conditions as appended:-

- 1.ABC 4.5Kg or 6Kg fire extinguishers should be kept and properly maintained in library.
- 2.Keep CO2 2Kg or 4.5Kg in Electrical Electronic Computer room and maintain properly.
- 3.Maintain first aid box in Head Teacher and Physical Education teacher's room.
- 4.Maintain the downstream and upstream water tank in the school with full capacity and proper protection.

Issued on **21.05.2024** (date of issue) at Nangavalli (place) by

Signature with Seal :



[Handwritten Signature]
21/5/2024
STATION OFFICER
Fire & Rescue Service Station
NANGAVALLI

Name : P.P.Saravanan
Designation : Station Officer
Name & Address of Department: Fire and Rescue Services,
Nangavalli, Salem DT

To
Meenampark Vidhyalaya School,
Mecheri - Salem Main Road,
Ponmalai, Periyasathapadi,
Salem - 636 453

Copyto:- 1.The Deputy Director,Salem Region,Salem.
2.District Officer, Salem District.